

EM/LE/55 Pt. II

895 8649

18 July 1994

All Registered Lift & Escalator Contractors  
All Registered Lift & Escalator Engineers

Dear Sirs,

**Circular No. 12/94**  
**Code of Practice on the Design and**  
**Construction of Lifts and Escalators (1993 Edition)**  
**- Amendment No. 3**

Your attention is drawn to the following typographic errors in the code:-

<u>Item</u>	<u>Clause</u>	<u>Correction</u>
1	Section E Part 1 Clause 4.11.2	Add "except that the doors shall open towards the inside of the car," after "apply,"
2	Section E Part 1 Clause 7.1	Add "The horizontal distance between the wall of the well and the sill or entrance frame of the car shall be within 150mm, unless an electrical safety device in conformity with Clause 10.2 is provided to prove the locking of the car door. This safety device cannot be in common with the device for proving the closed condition of the car door."
3	Section E Part 2	Add "4.2.4 <b>Overload Device</b> See Part 1 Clause 4.2.4"

Yours faithfully,

(M.S. KWOK)  
for Director of Electrical & Mechanical Services

c.c. AD/BS  
D of Housing

HKC/YWL/MSK/tp