

Lift Equipment Failure Incident reported to EMSD (from January to December 2011)

Contractor No.	Name of Contractor	Incident Date	Location	Incident Nature
RLC04002	Sigma Elevator (HK) Ltd.	06/01/11	Affluence Garden, Tuen Mun	Passenger's loss balance due to defective electrical component
		12/02/11	Kam Shun House, Kam Ying Court, Ma On Shan	Passenger entrapment due to defective lift door
RLC69001	Chevalier (HK) Ltd.	20/10/11	Kam Huen House, Kam Fung Court, Ma On Shan	Passenger entrapment due to defective electrical component
		12/12/11	Cheerful Court , 55 Choi Ha Road, Ngau Tau Kok	Passenger's loss balance due to fault signal of the levelling device
RLC74002	Schindler Lifts (Hong Kong) Ltd.	12/07/11	Kwong Tin Estate Shopping Centre, Lam Tin	Passenger's loss balance due to fault signal of the levelling device
		12/08/11	Tsz Fung House, Fung Tak Estate, Diamond Hill	Passenger entrapment due to defective electrical component
RLC75004	Otis Elevator Company (HK) Limited	04/01/11	199 Kowloon City Road, Tokwawan	Passenger entrapment due to fault signal of the electrical device
		28/01/11	Shin Lun House, Fu Shin Estate, Tai Po	Passenger entrapment due to defective electrical component
		21/03/11	Leung Wai House, Leung King Estate, Tuen Mun	Passenger entrapment due to defective floor selector
		13/06/11	Lee Tak Cheong Building, Cheung Sha Wan	Smoke due to overheat of the motor
		29/11/11	Wei Chien Court, Wylar Gardens, 2-10 Wai King Street, Tokwawan	Passenger's loss balance due to defective floor selector
		09/12/11	Chun King House , King Shing Court , Fanling	Passenger's loss balance due to fault signal of the levelling device
RLC80005	Holake Hong Kong Lifts Ltd.	13/05/11	Siu On Court, Tuen Mun	Passenger's loss balance due to defective lift door
RLC87001	KONE Elevator (HK) Ltd.	17/02/11	Tseung Kwan O MTR Station	Passenger entrapment due to defective lift door
		10/03/11	Ocean View, Ma On Shan	Stoppage of lift service due to fault signal of the control device
		25/05/11	Kwun Tong MTR Station	Passenger's loss balance due to defective electrical component
		31/05/11	Ocean View, Ma On Shan	Hand trapping due to defective electrical component
		27/08/11	East Tsim Sha Tsui MTR Station	Smoke due to overheat of the motor
		26/10/11	Belvedere Garden, Tsuen Wan	Passenger's loss balance due to defective electrical component
RLC88002	Chun Ming Engineering Co. Ltd.	08/11/11	Hong Ning Building, Cheung Sha Wan	Passenger's entrapment due to defective travelling cable
RLC91002	Nikkin Lifts & Escalators Limited	06/03/11	Kin Liong Mansion, 16-24 North Street, Kennedy Town	Passenger entrapment due to fault signal of the control device
		01/11/11	The VELA Hong Kong, 84-86 Morrison Hill Road, Wan Chai	Passenger entrapment due to defective levelling device
RLC92004	Anlev Elex Elevator Ltd.	04/06/11	Penta House, Sham Shui Po	Passenger entrapment due to defective electrical component
RLC94001	The Express Lift Company Limited	10/02/11	Marvel Industrial Building, Kwai Fung Crescent, Kwai Chung	Fire due to short circuit of electrical component
		04/04/11	1 Hung To Road, Kwun Tong	Passenger entrapment due to defective electrical component
		14/11/11	Marvel Industrial Building, Kwai Fung Crescent, Kwai Chung	Fire due to short circuit of electrical component
RLC97001	Jekco Elevator Ltd.	14/11/11	Mass Resources Development Building, 12-16 Humphreys Avenue, Tsim Sha Tsui	Passenger entrapment due to defective mechanical component
RLC97004	Ring Hing Engineering Services Co., Ltd.	16/06/11	Parkes Commercial Building, Jordan	Smoke due to defective transformer

No. of Equipment Failure Records = 28 (2 cases in December)