

機電工程處出版 Published by the Electrical and Mechanical Services Department
政府機電工程處印刷 Printed by the Government Logistics Department



冷氣機 安全須知

Safety Tips for Air-conditioners



電力法例  機電工程署

香港九龍啟成街 3 號
Electricity Legislation
Electrical and Mechanical Services Department
3 Kai Shing Street, Kowloon, Hong Kong
電話 Tel.: (852) 1823 傳真 Fax: (852) 2895 4929
網址 Homepage: www.emsd.gov.hk
電郵 E-mail: info@emsd.gov.hk



©Tazuka Productions
AT LICENSING & MERCHANDISING LTD. A Licensing Agent of Tazuka Productions Co., Ltd.

機電工程署  EMSD




不要在同一插座上接駁其他電器。

Do not connect other electrical appliances to the same socket outlet.





如冷氣機由固定線路供電，必須由註冊電業承辦商接駁。

If the power is supplied from a fixed electrical circuit, the connection work must be done by a registered electrical contractor.



若發現操作不正常(例如噪音或震動過大，或有異常氣味)，應立即停用及安排維修。

If any abnormalities (e.g. excessive noise or vibration, or abnormal smell) are found, stop the unit and arrange for repair.





停
STOP



房間不需使用時，應關掉電源。

Turn off the switch when the room is not in use.



安排定期保養。

Arrange for regular maintenance.

