

**CONTROLLING OFFICER'S REPLY TO
INITIAL WRITTEN QUESTION**

ENB041

Question Serial No.

2354

Head: 42 – Electrical and Mechanical Services Department

Subhead (No. & title):

Programme: (1) Energy Supply; Electrical, Gas and Nuclear Safety

Controlling Officer: Director of Electrical and Mechanical Services

Director of Bureau: Secretary for the Environment

Question:

- a) Regarding the periodic testing certificates of electrical installations processed for electrical safety, please provide the number of periodic test certificates issued in the past 5 years according to the type of electrical installations as stipulated in the following table:

	Installation required to be inspected, tested and certified at least once every 12 months according to Regulation 20(1) of the Cap. 406E			Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(2) of Cap. 406E)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(3) of Cap. 406E), other than those premises referred to in sub-regulation (1) or (2)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(4) in Cap. 406E)								
	(a)	(b)	(c)			(a)	(b)	(c)	(d)	(e)	(f)			
2011														
2010														
2009														
2008														
2007														

- b) With regard to the above breakdown records, please provide the number of conviction for owner of electrical installation failing to arrange the required periodic inspection and testing works.

	Installation required to be inspected, tested and certified at least once every 12 months according to Regulation 20(1) of the Cap. 406E			Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years in a factory or industrial undertaking (Regulation 20(2) of Cap. 406E)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(3) of Cap. 406E), other than those premises referred to in sub-regulation (1) or (2)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(4) in Cap. 406E)					
	(a)	(b)	(c)			(a)	(b)	(c)	(d)	(e)	(f)
2011											
2010											
2009											
2008											
2007											

Asked by: Hon. LI Fung-ying

Reply:

(a) The required information regarding the number of periodic test certificates processed is summarized below:


	Installation required to be inspected, tested and certified at least once every 12 months according to Regulation 20(1) of the Cap. 406E			Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(2) of Cap. 406E)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(3) of Cap. 406E), other than those premises referred to in sub-regulation (1) or (2)	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(4) in Cap. 406E)					
	(a)	(b)	(c)			(a)	(b)	(c)	(d)	(e)	(f)
2011	268	1 704	237	128	5 865	111	50	421	61	87	27
2010	250	1 649	198	97	6 051	150	69	415	49	59	0
2009	260	1 730	199	175	6 368	110	47	255	57	48	0
2008	260	1 655	147	181	6 535	126	33	285	70	36	0
2007	267	1 749	164	181	6 472	102	27	354	71	59	0

(b) The required information regarding the number of conviction for owner of electrical installation is summarized below:

	Installation required to be inspected, tested and certified at least once every 12 months according to Regulation 20(1) of the Cap. 406E			Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years in a factory and industrial	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(3) of Cap. 406E), other than	Low voltage fixed electrical installation required to be inspected, tested and certified at least once every 5 years (Regulation 20(4) in Cap. 406E)					
	(a)	(b)	(c)			(a)	(b)	(c)	(d)	(e)	(f)

				undertaking (Regulation 20(2) of Cap. 406E)	those premises referred to in sub- regulation (1) or (2)						
2011	0	0	0	0	101 installations involving 1 133 owners	0	0	0	0	0	1 installation involving 11 owners
2010	0	0	0	0	66 installations involving 1 413 owners	0	0	0	0	0	0
2009	0	0	0	0	32 installations involving 439 owners	0	0	0	0	0	0
2008	0	0	0	0	69 installations involving 646 owners	0	0	0	0	0	0
2007	0	0	0	0	88 installations involving 169 owners	0	0	0	0	0	0

Signature: _____



Name in block letters: _____

CHAN Fan

Post Title: _____

Director of Electrical and Mechanical Services

Date: _____

23 February 2012