


Briefing Session on Buildings Energy Efficiency Ordinance for Registered Energy Assessors





Agenda



- Enforcement work
- Submissions under the BEEO
- Frequently asked questions



Enforcement Work




Publicity

- More than 90 nos. briefings / seminars since Jan 2011
 - covering academia, professionals, engineering trades, business sector, property management companies and building owners, etc.
 - more than 7,000 audiences attended
- Technical papers were presented in seminars / conferences; articles were published in journals and publications
- TV and radio broadcasting since July 2012
 - TV API posted to EMSD Video Channel on YouTube (English Version)

http://www.youtube.com/watch?v=sG2b8fi54yE (Chinese Version)

http://www.youtube.com/watch?v=Sq8hcND3qxc





Enforcement Work (cont'd)



Inspection

Checking of document submissions

 e.g. For submissions regarding energy audit: Energy Audit Form, Energy Audit Checklist, Executive Summary and energy audit report

Site visits / inspections

 e.g. To check whether a valid Energy Audit Form is exhibited in a building; electricity bills and BS equipment schedule etc.

Monitor compliance

 e.g. To check the completion date of "major retrofitting works" and whether the issue date of Form of Compliance is within 2 months after the completion date etc.



Enforcement Work (cont'd)



- Close liaison with various organizations and government departments to collect information of buildings and major retrofitting works
- Advisory letters to developers, building owners, property management companies and responsible persons to draw their attention on the BEEO requirements



Submissions under the BEEO



Change of REA particulars

- For any change in name/ correspondence address, REA should notify EMSD of the change within 28 days using Form EA1 (Section 11 (1) of Cap 610B)
 - A person who contravenes section 11(1) is liable on conviction to a fine of \$2,000.







Change of REA particulars

- For any change in correspondence email/ telephone no., REA should use Form EA1 to notify EMSD as soon as possible
- For any change in email/ telephone no. disclosed on the BEEO's website, REA should email EMSD through mbec@emsd.gov.hk to obtain the form for disclosure of contact information and submit the completed application with signature by email or by fax






Stage one declaration

	Consent to the commencement of -			
	Alterations and additions	Building works for foundation	Building works for superstructure	Building works for both foundation and superstructure
Submission of "stage one declaration" within 2 months after the issue date of consent by the developer	×	*	✓	✓







Stage two declaration

- Within 4 months after the day on which OP is issued
- Personally inspected the BS installations by REA in 30 days before certification (Section 9(3) of Cap 610)





	Section B 乙 部:Declaration 聲明				
	To 致: Building owner 建築物擁有人 Cc 副本抄送:The Director of Electrical and Mechanical Services 機電工程署署長 (see note 5 overleaf 見背頁須知事項 5) In accordance with section 22 of the Buildings Energy Efficiency Ordinance (Chapter 610), I, (full name)				
	In accordance with section 22 of the Buildings Energy Efficiency Ordinance (Chapter 610), I, (full				
	name), Registered Energy Assessor (Registration				
	No.:), certify that an Energy Audit in respect of the above				
	building was completed on/ / (DD/MM/YYYY). This Energy Audit Form will				
	expire on / / / (DD/MM/YYYY). (see note 4 overleaf)				
機電工程署 EMSD					
Energy Audit	 Energy Audit Form is valid for 10 years Expiry date = the last day of 10-year period Within 30 days after issuing an Energy Audit 				
Form (Form EE5)	Form, REA should send a copy of Energy Audit Form and an energy audit report to EMSD				

(Section 22(5) of Cap 610)





Submission of Energy Audit Report



Frequently asked questions



Major Retrofitting Works

Either

Works Area

Addition/replacement of a BS installation specified in the BEC at the following conditions –

total floor area covered by the works (i.e. works area) ≥ 500 m² in a unit or a common area

If the works are conducted as a same series of works in phases or at different places in a unit or a common area, total floor area covered by these works (i.e. works area) within 12 months aggregating to ≥ 500 m²

OR Central BS installation

Addition/replacement of a main component of a central BS installation, either –



a complete electrical circuit at rating ≥ 400A;

or




a unitary air-conditioner or a chiller at rating ≥ 350kW (cooling or heating);

or



motor drive + mechanical drive of a lift, escalator or passenger conveyor





Question:


What are the technical requirements of the BEEO for "major retrofitting works"?

Answer:

The technical requirements of "major retrofitting works" can be found in Table 10.1 of BEC 2012 Edition.







Floor area
 ≥ 500 m²








Table 10.1
Major Retrofitting Works and Energy Efficiency Requirements

Category of Major Retrofitting Work

Condition for Applicability of BEC Requirement

Applicable BEC Requirement

BEC Clause No.

- (a) Works involving addition or replacement of a building services installation that covers one or more places with a floor area or total floor area of not less than 500 m² under the same series of works within 12 months in a unit or a common area should include item (i), item (ii) and/or item (iii) as described below (please also see the remarks at the end of this table)
 - addition or replacement luminaire(s)

total circuit wattage of the additional or replacement luminaires at or exceeding 3kW


no existing luminaires in the lighting power area, or the sum of circuit wattage of additional or replacement luminaires is more than that of 50% of the original luminaires in the area

density

5.4







2. Main component of central building services installation








Table 10.1 Major Retrofitting Works and Energy Efficiency Requirements				
Category of Major Retrofitting Work	Condition for Applicability of BEC Requirement	Applicable BEC Requirement	BEC Clause No.	
(ii) addition or replacement	applicable in any conditions	air- conditioning equipment efficiency	6.12	
of a unitary air-	the work involving for the additional or replacement air-conditioning equipment the	frictional loss of water piping system	6.9	
conditioner or a chiller of	addition or complete replacement of corresponding water side pumping system	energy metering	6.13	
a cooling or heating	ditto, the corresponding water side pumping system forming an independent system	pumping system variable flow	6.8	
rating at or exceeding	the work involving addition or replacement of pipework, ductwork or AHU	thermal insulation	6.11	
350kW	the work involving addition or replacement of water pump with new motor, of AHU with new motor, or of fan with new motor	motor efficiency	7.5.1	



Energy Audit

- Energy audit requirements apply to:
 - commercial buildings
 - commercial portion of composite buildings
- "Commercial building" means a building that is:-
 - used for offices, shops or entertainment facilities; or
 - used for the purpose of any trade, business or profession (but not used as an industrial building)





Question:

Is it required to carry out energy audit for the central building services installation (CBSI) of hotels and guest houses?



Answer:

NOT required because hotels and guest houses are categorized as a separate type of building according to Schedule 1 of the BEEO, and hence are not regarded as commercial buildings in which energy audit requirement is applicable.





Question:

Is it required to carry out energy audit for the CBSI of a car park?

A				
Answer:	Energy audit			
Commercial building	\checkmark			
Residential building	×			
Industrial building	×			
Composite building (e.g. industrial + commercial / residential + commercial)	√ (With CBSI of car park for commercial portion)			

Demarcation of central building services installation (CBSI) and non-CBSI in units in buildings with common area and buildings without common area				
Building type	Ownership or tenement of area or unit served by concerned building services installation (BSI)	Ownership of BSI	BSI regarded as CBSI or non-CBSI	Justification for being CBSI or non-CBSI based on interpretation in the Ordinance (Cap 610)
Building with common	Entrance lobby, common corridor, staircase etc. (i.e. the common area interpreted in the Ordinance)	Building owner	CBSI	BSI not solely serving a unit
area	Building owner occupied unit	Building owner	Non-CBSI	BSI solely serving a unit
	Occupier owned unit	Building owner		
		Unit occupier		
	Leased unit	Building owner		
		Unit lessee		
Building without common area	Entrance lobby, common corridor, common staircase etc.	Building owner	CBSI	BSI owned by the building owner (and not solely serving a unit)
	Building owner occupied unit	Building owner	CBSI	BSI owned by the building

Building with common area	Entrance lobby, common corridor, staircase etc. (i.e. the common area interpreted in the Ordinance)	Building owner	CBSI	BSI not solely serving a unit
	Building owner occupied unit	Building owner	Non-CBSI	BSI solely serving a unit
	Occupier owned unit	Building owner		
		Unit occupier		
	Leased unit	Building owner		
		Unit lessee		
Building without common	Entrance lobby, common corridor, common staircase etc.	Building owner	CBSI	BSI owned by the building owner (and not solely serving a unit)
area	Building owner occupied unit	Building owner	CBSI	BSI owned by the building owner
	Leased unit			
	Leased unit	Unit lessee	Non-CBSI	BSI solely serving a unit and owned by a person who is not the building owner




Question:

If there is a non-domestic portion in a residential building according to the "occupation permit", is this building regarded as a residential building or a composite building?

Answer:

This building is regarded as a composite building. If the non-domestic portion is a commercial one, energy audit may be required, depending on whether there is any CBSI within the area.







Question:

Should exit sign/ display lighting be taken into account when calculating lighting power density (LPD)?



Answer:

According to the clause 5.1.2(d) of the BEC, lighting installation integral to a signage is not covered by the BEEO. According to the Schedule 2 of the BEEO, display lighting is also not covered. Therefore, they should not be counted in the LPD calculation.



Way forward




- Technical guidelines for BEC and EAC 2012 Edition are being finalized
- Revised Energy Audit Form (Form EE5) and Executive Summary (Form EE-EAes) will be in effect soon
- Energy efficiency standards of BEC will be reviewed with reference to the latest developments of relevant technology and practices




BEEO's Website











Energy Efficiency Office

能源效益事務處

Enquiry: 37576156

Email: mbec@emsd.gov.hk

Address: 3 Kai Shing Street, Kowloon

Website: http://www.beeo.emsd.gov.hk





Q&A Session

