

根據強制性能源效益標籤計劃 (強制性標籤計劃) 進行的能源表現監察測試結果 (空調機) - 2026年
Results of Compliance Monitoring Tests on Energy Performance under Mandatory Energy Efficiency Labelling Scheme (MEELS)
(Room Air Conditioners) - Year 2026

項目 No.	品牌 Brand	型號 Model Name	獲機電工程署編配參考編號 EMSD Assigned Reference Number	強制性標籤計劃下的能源效益級別 Energy Efficiency Grade under MEELS	額定制冷量 (千瓦) ^{註2} Rated Cooling Capacity (kW) ^{Note 2}	額定制冷功率消耗量 (額定制冷量) (千瓦) ^{註2} Rated Cooling Power Consumption (Rated Wattage) (kW) ^{Note 2}	額定制暖量 (千瓦) ^{註2} Rated Heating Capacity (kW) ^{Note 2}	額定制暖功率消耗量 (額定制暖量) (千瓦) ^{註2} Rated Heating Power Consumption (Rated Wattage) (kW) ^{Note 2}	測試出的製冷量 (千瓦) ^{註2} Measured Cooling Capacity (kW) ^{Note 2}	測試出的製冷功率消耗量 (測試出的瓦數) (千瓦) ^{註2} Measured Cooling Power Consumption (Measured Wattage) (kW) ^{Note 2}	測試出的供暖量 (千瓦) ^{註2} Measured Heating Capacity (kW) ^{Note 2}	測試出的供暖功率消耗量 (測試出的瓦數) (千瓦) ^{註2} Measured Heating Power Consumption (Measured Wattage) (kW) ^{Note 2}	是否符合強制性標籤計劃的要求? ^{註1} Conformance with MEELS Requirements? ^{Note 1}	備註 Remark
測試結果發放日期: 2026年05月 Test Results Release Date: May 2026														
1	三菱電機 MITSUBISHI ELECTRIC	MSZ-LN12VFB / MUZ-LN12VF	U1-C200135	1	3.50	0.82	4.00	0.82	3.64	0.81	3.94	0.82	是 Yes	
2	LG	HS-12IPX	U1-C210075	1	3.30	0.84	N/A	N/A	3.31	0.82	N/A	N/A	是 Yes	
3	格力 GREE	GSY12BXAE / GSY12BXAC	U1-C230107	1	3.53	0.80	4.20	0.93	3.71	0.79	4.28	0.92	是 Yes	
4	大金 DAIKIN	FTX35MV1HW / RXJ35MV1H	U1-C240059	1	3.50	0.86	3.50	0.73	3.74	0.88	3.53	0.73	是 Yes	
5	樂信牌 Rasonic	RS-RZ12BK / RU-RZ12BK	U1-C240133	1	3.50	0.88	4.00	1.00	3.64	0.92	4.10	1.03	是 Yes	
6	Panasonic	CS-RZ12BKA / CU-RZ12BKA	U1-C240141	1	3.50	0.88	4.00	1.00	3.66	0.88	4.06	0.98	是 Yes	
7	三星 Samsung	AR60F12D1BWNH	U1-C250004	1	3.50	1.05	N/A	N/A	3.70	1.08	N/A	N/A	是 Yes	
8	美的 Midea	MS-12CRF8F	U1-C250046	1	3.50	1.13	N/A	N/A	3.65	1.10	N/A	N/A	是 Yes	
9	珍寶 General	ASWH12KNCA / AOWH12KNCA	U1-C250068	1	3.40	0.96	4.00	1.00	3.61	0.95	4.07	0.99	是 Yes	
10	MECAN	MC12WMIP / MC12WMOP	U1-C250218	1	3.52	0.85	N/A	N/A	3.41	0.90	N/A	N/A	是 Yes	
11	開利 Carrier	42KHE012V8S / 38KHE012V8S	U1-C250255	1	3.52	0.85	N/A	N/A	3.48	0.89	N/A	N/A	是 Yes	
12	三菱重工 MHI	SRK35ZSXH-WF / SRC35ZSXH-W	U1-C250259	1	3.50	0.74	4.30	0.90	3.65	0.74	4.47	0.91	是 Yes	
13	天松 TOSOT	S12VC200N / S12VC200U	U1-C250293	1	3.55	1.02	N/A	N/A	3.68	1.03	N/A	N/A	是 Yes	

註: 1. 如空調機某表列型號的單一標本的測試結果符合以下標準(產品能源標籤實務守則2024第7.11段), 則該表列型號會獲接納為符合有關規定:

- 在標準製冷條件 (T1 氣候) 下進行最大製冷輸出測試所測試出的製冷量 $\phi_{cl}(35)$, 不低於其額定制冷量的 90%。在標準供暖條件 (H1 氣候) 下進行最大供暖輸出測試所測試出的供暖量 $\phi_{h1}(7)$, 不低於其額定制暖量的 90%;
- 在標準製冷條件 (T1 氣候) 下進行最大製冷輸出測試所測試出的功率消耗量 $P_{cl}(35)$, 不高於其額定制冷功率消耗量的 110%。在標準供暖條件 (H1 氣候) 下進行最大供暖輸出測試所測試出的功率消耗量 $P_{h1}(7)$, 不高於其額定制暖功率消耗量的 110%;
- 計算出的製冷季節性表現係數不得低於其額定制冷季節性表現係數的 92%。計算出的供暖季節性表現係數不得低於其額定制暖季節性表現係數的 92%;
- 附有第 1、2、3 或 4 級能源標籤的淨製冷型及逆轉循環型空調機已通過最大製冷表現測試。附有第 1、2、3 或 4 級能源標籤的逆轉循環型空調機已通過最大供暖表現測試; 及
- 所測試出的能源效益級別符合以下其中一項規定:
 - 在監察測試中所計算出的製冷能源效益級別, 相等於指明人士向機電工程署呈交的測試結果所釐定的製冷能源效益級別或較該級別為佳。在監察測試中所計算出的供暖能源效益級別, 相等於指明人士向機電工程署呈交的測試結果所釐定的供暖能源效益級別或較該級別為佳; 或
 - 在監察測試中所計算出的製冷能源效益級別, 如不等於向機電工程署呈交的測試結果所釐定的製冷能源效益級別或較該級別為差, 則在監察測試中所計算出的製冷季節性表現係數, 不得低於向機電工程署呈交的測試結果所計算出的製冷季節性表現係數的 92%, 並在任何情況下都不低於下一個較低製冷能源效益級別所允許的最低製冷季節性表現係數。如在監察測試中所計算出的供暖能源效益級別, 不等於向機電工程署呈交的測試結果所釐定的供暖能源效益級別或較該級別為差, 則在監察測試中所計算出的供暖季節性表現係數, 不得低於向機電工程署呈交的測試結果所計算出的供暖季節性表現係數的 92%, 並在任何情況下都不低於下一個較低供暖能源效益級別所允許的最低供暖季節性表現係數。
(註: 製冷季節性表現係數用作釐定產品能源效益級別, 如欲了解詳細的計算方法, 可參閱產品能源標籤實務守則2024第 7.6 段。)

2. 表列的數值經四捨五入方式顯示。

Note: 1. A listed model of room air conditioner will be accepted as conformance if the test results of a single sample of the listed model meet the following criteria (clause 7.11 of the Code of Practice on Energy Labelling of Products 2024 (the Code)):

- The tested cooling capacity $\phi_{cl}(35)$ from cooling full capacity test at standard cooling condition (T1 climate) being not less than 90% of the rated cooling capacity. The tested heating capacity $\phi_{h1}(7)$ from heating full capacity test at standard heating condition (H1 climate) being not less than 90% of the rated heating capacity;
- The tested power consumption $P_{cl}(35)$ from cooling full capacity test at standard cooling condition (T1 climate) being not greater than 110% of the rated power consumption. The tested power consumption $P_{h1}(7)$ from heating full capacity test at standard heating condition (H1 climate) being not greater than 110% of the rated power consumption;
- The calculated cooling seasonal performance factor being not less than 92% of the rated cooling seasonal performance factor. The calculated heating seasonal performance factor being not less than 92% of the rated heating seasonal performance factor;
- The cooling only type and reverse cycle type room air conditioner (with a Grade 1, 2, 3 or 4 energy label) passing the maximum cooling performance test. The reverse cycle type room air conditioner (with a Grade 1, 2, 3 or 4 energy label) passing the maximum heating performance test; and
- The tested energy efficiency grade meeting either one of the following:
 - The cooling energy efficiency grade calculated in the compliance monitoring testing being equal to or better than the cooling energy efficiency grade determined by the test results submitted to the EMSD by the specified person. The heating energy efficiency grade calculated in the compliance monitoring testing being equal to or better than the heating energy efficiency grade determined by the test results submitted to the EMSD by the specified person; or

- (ii) If the cooling energy efficiency grade calculated in the compliance monitoring testing being not equal to nor better than the cooling energy efficiency grade determined by the test results submitted to the EMSD, the cooling seasonal performance factor calculated in the compliance monitoring testing being not less than 92% of the cooling seasonal performance factor calculated by the test results submitted to the EMSD, and in any cases not less than the lowest cooling seasonal performance factor allowed in the next lower cooling energy efficiency grade. If the heating energy efficiency grade calculated in the compliance monitoring testing being not equal to nor better than the heating energy efficiency grade determined by the test results submitted to the EMSD, the heating seasonal performance factor calculated in the compliance monitoring testing being not less than 92% of the heating seasonal performance factor calculated by the test results submitted to the EMSD, and in any cases not less than the lowest heating seasonal performance factor allowed in the next lower heating energy efficiency grade.

(Remark: Cooling seasonal performance factor is used to determine the energy efficiency grade of a product. Please refer to clause 7.6 of the Code of Practice on Energy Labelling of Products 2024 for details of calculation method.)

2. All values are rounded figures.