

**Addendum No. 01/2023**  
**增編第 01/2023 號**  
**Addendum for Code of Practice for Hong Kong LPG Industry**  
**Module 9 – LPG Cylinders**  
**香港石油氣業工作守則 第9單元 石油氣瓶 的增編**

(Taking effect from 1 April 2024)  
2024年4月1日起生效

<b>Clause</b> 段落	<b>Added clause</b> 新增段落
7.6	<u>English Edition</u>  Cylinder valves provided for cylinder for withdrawing liquefied petroleum gas in vapour form shall be equipped with self-closing feature which only enables gas to flow when a gas tight connection is made.
	<u>中文版</u>  供抽取氣態石油氣用的石油氣瓶氣閥須備有自動關閉功能，只可在氣體配件接駁穩妥後，氣體才能從氣瓶流出。
8.12	<u>English Edition</u>  LPG cylinders carrying out revalidation test shall comply with the requirements stated in Clause 7.6 of this Code of Practice.
	<u>中文版</u>  接受覆檢測試的石油氣瓶須跟從本工作守則第7.6段的要求。