

***Addendum No. 1 to
Guidelines on Energy Efficiency of Air Conditioning Installations***

Following the Review in end 2004/05, there is the following amendment:

Replace sub-item 7.3.3 on Page 24 with the following:

**Set office room temperature to 25.5⁰C, allowing the relative humidity to fluctuate.
Turn off cooling immediately when unoccupied.**