

List of Warning Letters Issued to Registered Escalator Contractors (January 2025 to December 2025)

(1) 15 PM points non-compliant item(s) found, or conviction by the court/disciplinary board <sup>Note1</sup>

Month	Contractor No.	Name of Contractor	Brief Content of Warning Letter
-	-	-	-

(2) A total of 12 PM points or more involving maintenance non-compliant item(s) found in a single escalator inspection, or the average PM points exceeding 4 PM points within a 12-month period, or failure to comply with the provisions of the Lifts and Escalators Ordinance <sup>Note2</sup>

Month	Contractor No.	Name of Contractor	Brief Content of Warning Letter
-	-	-	-

The EMSD will issue a warning letter to the contractor under the following situations:-

Note 1: - 15 PM points non-compliant item(s) found in a single escalator inspection, or conviction by the court/ disciplinary board;

Note 2: - A total of 12 PM points or more involving maintenance non-compliant item(s) found in a single escalator inspection;

- The average PM points exceeding 4 PM points within a 12-month period; or
- Failure to comply with the provisions of the Lifts and Escalators Ordinance.