

Contractors' Performance Rating (CPR) of Registered Lift Contractor (From December 2010 to November 2011) (Note 1) (in alphabetical order)

Name of Contractors	Contractor No.	No. of prosecution cases in the assessment period	No. of disciplinary cases in the assessment period	Previous Performance Index (September 2010 to August 2011)	December 2010 to November 2011				
					Cumulated Maintenance PM Points	No. of Lifts Inspected	Maintenance Index (Note 2)	Safety Index (Note 2)	Performance Index
Anlev Elex Elevator Ltd.	RLC92004			86	6	45	43	50	93
Antonfield Engineering Co., Ltd.	RLC95002			92	0	19	50	50	100
Associated Engineers, Ltd.	RLC01003			100	0	7	50	50	100
Association Electrical Engineering Limited	RLC02003			100	0	24	50	50	100
Ben Fung Machineries & Engineering Ltd	RLC73001			100	0	36	50	50	100
Cheerwell Engineering Limited	RLC96002			100	0	11	50	50	100
Chevalier (HK) Limited	RLC69001			97	10	366	49	50	99
Chun Ming Elevator Co. Ltd.	RLC93002	1		78	8	36	39	50	89
Chun Ming Engineering Co. Ltd.	RLC88002		1	96	8	87	45	50	95
CKP Building Service Systems Ltd.	RLC85001			50	6	10	20	50	70
Elevator Parts Engineering Company Limited	RLC78001			74	6	30	40	50	90
Eugene Engineering Co. Limited	RLC03002			93	4	29	43	50	93
Fujitec (HK) Co. Ltd.	RLC85005			92	10	364	49	50	99
Hitachi Elevator Engineering Co. (HK) Ltd.	RLC67001			81	6	118	47	35	82
Hoi Fai Lift Engineering & Services Ltd.	RLC87006			100	0	11	50	50	100
Holake Hong Kong Lifts Ltd.	RLC80005			90	14	176	46	50	96
Hongkong International Terminals Limited	RLC01004			100	0	17	50	50	100
Jekco Elevators Ltd.	RLC97001			71	16	29	22	50	72
KONE Elevator (HK) Ltd.	RLC87001			90	38	242	42	50	92
Lighthouse Elevator Engineering Limited	RLC98003			56	48	81	20	50	70
Mitsubishi Elevator Hong Kong Company Limited	RLC88005			99	6	476	49	50	99
Nikken Lifts & Escalators Limited	RLC91002			77	90	242	31	20	51
Otis Elevator Company (HK) Limited	RLC75004	2		83	164	602	36	50	86
Rich Mark Engineering Limited	RLC99001			97	3	66	48	50	98
Ring Hing Engineering Services Co., Ltd.	RLC97004			83	61	55	0	50	50
Ryoden Lift Services Limited	RLC99002			81	0	30	50	50	100
Schindler Lifts (Hong Kong) Ltd	RLC74002			90	79	461	41	50	91
Shan On Engineering Company Limited	RLC73002			95	6	65	45	50	95
Shineford Engineering Limited	RLC97002			100	12	14	7	50	57
Sigma Elevator (HK) Ltd.	RLC04002			70	32	81	30	50	80
Sun Fai Engineering & Equipment Co., Ltd.	RLC02002			63	0	13	50	50	100
Techfaith Engineering Limited	RLC00002			50	40	9	0	50	50
The Express Lift Company Limited	RLC94001			92	40	132	35	50	85
ThyssenKrupp Elevator (HK) Limited	RLC96001		1	94	66	123	23	50	73
Toki Elevator Engineering Ltd.	RLC85002			72	23	40	21	50	71
Vertex Engineering Limited	RLC00001			100	0	13	50	50	100

Note 1 : For a better reflection of the contractors' performance in the assessment period, only the CPR results of Contractors whose installations have been inspected by EMSD for 5 times or more will be included in the table. It does not include (a) the contractors whose installations have been inspected by EMSD are less than 5 times and (b) contractors who do not undertake any lift maintenance work during the assessment period.

(a) Contractors whose installations have been inspected by EMSD were less than 5 times during the assessment period

Name of Registered Lift Contractor	Contractor No.
Amanli (HK) Lift & Escalator Engineering Limited	RLC03001
Loedige Asia Limited	RLC07001
Taizoom Elevator Company (H.K.) Limited	RLC10001
Tak Lee Elevator Engineering Co., Ltd.	RLC02001

(b) Contractors who did not undertake any lift maintenance work during the assessment period

Name of Registered Lift Contractor	Contractor No.
Group Creation International Limited	RLC04001
Holake (HK) Ltd.	RLC76001
MTR Corporation Ltd.	RLC78003
Ryoden Elevator Company Limited	RLC64001
Whole Safe Ltd.	RLC92001

Note 2 : Performance Index (Full mark of 100) = Maintenance Index (0 to 50 marks) + Safety Index (0 to 50 marks); Maintenance Index = 50 x (1- cumulated maintenance performance monitoring points / number of inspections in the period); Safety Index = 50 - cumulated safety performance monitoring points (each critical safety non-compliant item with 15 Points). The cumulated performance monitoring points are valid for 12 months. Details of the maintenance and safety items can be observed from http://www.emsd.gov.hk/emsd/e_download/pps/circular/A3/2_2011.pdf.