

Lift Equipment Failure Incident reported to EMSD (January 2018 to December 2018)

Contractor No.	Name of Contractor	Incident Date	Location	Incident Nature
RLC69001	Chevalier (HK) Ltd.	25/01/2018	Water Services Department, Argyle Street, Kowloon	Malfunction of lift car leveling system resulting in passenger injury
RLC75004	Otis Elevator Company (H.K.) Ltd.	06/02/2018	Siu Hang House, Siu Hong Court, Tuen Mun, N.T.	Malfunction of lift car leveling system resulting in passenger injury
RLC04002	Sigma Elevator (HK) Limited	22/03/2018	Sai Kung Market, 67 Yi Chun Street, Sai Kung, N.T.	Malfunction of electrical component resulting in passenger injury
RLC98003	Lighthouse Elevator Engineering Ltd	30/03/2018	Yiu Ming House, Wah Ming Estate, Fanling, N.T.	Malfunction of control system resulting in passenger injury
RLC73001	Ben Fung Machineries & Engineering Ltd.	08/04/2018	Block 2, Waterside Plaza, Tsuen Wan, N.T.	Ineffective braking system resulting in passenger injury
RLC04002	Sigma Elevator (HK) Ltd.	29/04/2018	Vigor Industrial Building, 14-20 Cheung Tat Road, Tsing Yi, N.T.	Malfunction of lift car leveling system resulting in passenger injury
RLC03002	Eugene Engineering Co. Ltd.	11/05/2018	Paris Court, Sheung Shui Town Centre, 9 Chi Cheong Road, Sheung Shui, N.T.	Ineffective braking system resulting in passenger death
RLC80005	Holake Hong Kong Lifts Ltd.	30/07/2018	Mayland Court, 1-7 Shelter Street, Causeway Bay, Hong Kong	Malfunction of lift car leveling system resulting in passenger injury
RLC74002	Schindler Lifts (HK) Ltd.	23/08/2018	Block 1, Gateway, Harbour City, 25 Canton Road, Tsim Sha Tsui, Kowloon	Malfunction of lift car leveling system resulting in passenger injury
RLC75004	Otis Elevator Company (H.K.) Ltd.	22/10/2018	Metro Plaza, 223 Hing Fong Road, Kwai Chung, N.T.	Malfunction of lift car leveling system resulting in passenger injury
RLC91002	Nikkin Lifts & Escalators Ltd.	23/10/2018	Ming Fung Court, 39-41 Ming Fung Street, Wong Tai Sin, Kowloon	Occurrence of unintended car movement
RLC69001	Chevalier (HK) Ltd.	28/10/2018	Shatin Galleria, 18-24 Shan Mei Street, Sha Tin, N.T.	Malfunction of electrical component resulting in passenger injury
RLC91002	Nikkin Lifts & Escalators Ltd.	06/11/2018	Ming Fung Court, 39-41 Ming Fung Street, Wong Tai Sin, Kowloon	Occurrence of unintended car movement
RLC04002	Sigma Elevator (HK) Limited	21/11/2018	Vigor Industrial Building, 14-20 Cheung Tat Road, Tsing Yi, N.T.	Malfunction of mechanical component resulting in passenger injury
RLC04002	Sigma Elevator (HK) Limited	23/11/2018	Kwai Tai House, Kwai Fong Estate, Kwai Chung, N.T.	Malfunction of lift car leveling system resulting in passenger injury

No. of Equipment Failure Records = 15