

**Lift Equipment Failure Incident reported to EMSD (Jan 2024 to Mar 2024)**

<b>Contractor No.</b>	<b>Name of Contractor</b>	<b>Incident Date</b>	<b>Location</b>	<b>Incident Nature</b>
RLC74002	Schindler Lifts (Hong Kong) Ltd.	11/02/2024	Discovery Park, 398 Castle Peak Road, Tsuen Wan, N.T.	Passenger tripping due to levelling difference of lift car at landing arisen from malfunction of electrical component

No. of Equipment Failure Records = 1