

Lift Equipment Failure Incident reported to EMSD (from January 2015 to December 2015)

Contractor No.	Name of Contractor	Incident Date	Location	Incident Nature
RLC74002	Schindler Lifts (Hong Kong) Ltd.	21/12/2014 ^{Note 1}	Yuen Kee International Building, 3 Queen's Victoria Street, Hong Kong	Passenger injury due to malfunction of electrical components
RLC75004	Otis Elevator Company (HK) Ltd.	05/02/2015	Metroplaza, 223 Hing Fong Road, Kwai Chung, N.T.	Passenger injury due to malfunction of lift car leveling system
RLC04002	Sigma Elevator (HK) Ltd.	24/02/2015	Coin Organize Building, 67C Waterloo Road, Mongkok, Kowloon	Passenger injury due to falling of lift car ceiling component
RLC87001	KONE Elevator (HK) Limited	07/04/2015	Lai Wo House, Tai Wo Estate, Tai Po, N.T.	Passenger injury due to malfunction of lift car leveling system
RLC80005	Holake Hong Kong Lifts Ltd.	23/04/2015	Hewlett Centre, 52-54 Hoi Yuen Road, KTIL 56, Kwun Tong, Kowloon	Brake failure due to malfunction of electrical components
RLC75004	Otis Elevator Company (HK) Ltd.	18/05/2015	The Prince Philip Dental Hospital, 34 Hospital Road, Sai Ying Pun, Hong Kong	Passenger injury due to malfunction of electrical components
RLC80005	Holake Hong Kong Lifts Ltd.	15/06/2015	Humphreys Building, 11 Humphreys Avenue, Tsim Sha Tsui, Kowloon	Passenger injury due to malfunction of electrical components
RLC85005	Fujitec (HK) Company Limited	14/07/2015	Ravana Garden, 1-3 On King Street, Sha Tin, N.T.	Passenger injury due to malfunction of lift car leveling system
RLC87001	KONE Elevator (HK) Limited	09/11/2015	9 Tuen Hing Road, Villa Tiara, Tuen Mun	Passenger injury due to malfunction of mechanical components
RLC69001	Chevalier (HK) Limited	25/12/2015	Cambridge Plaza, San Wan Road, Sheung Shui, N.T.	Passenger injury due to falling of lift door component
RLC96001	ThyssenKrupp Elevator (HK) Limited	26/12/2015	Choi Po Court, 2 Choi Yuen Road, Sheung Shui, N.T.	Passenger injury due to malfunction of lift car leveling system

No. of Equipment Failure Records = 11

Note 1: Incident is recorded in 2015.