

**Lift Equipment Failure Incident reported to EMSD (from January to December 2013)**

Contractor No.	Name of Contractor	Incident Date	Location	Incident Nature
RLC97002	Shineford Engineering Limited	02/03/2013	King's Tower, 478-480 King's Road, North Point	Passenger injury due to breakage of suspension rope
RLC69001	Chevalier (HK) Ltd.	08/03/2013	Golden Building, 146-152 Fuk Wa Street, Sham Shui Po	Stoppage of lift service due to defective electrical component
		16/06/2013	Fu Wen House, Fu Cheong Estate, Sham Shi Po	Passenger injury due to fault signal
		25/08/2013	Block L, Amoy Garden, Phase III, Ngau Tau Kok	Passenger injury due to fault signal
RLC74002	Schindler Lifts (HK) Ltd.	19/06/2013	Leung Wah House, Leung King Estate, Tuen Mun	Passenger injury due to fault signal

No. of Equipment Failure Records = 5