


# 定期做好5年檢 電力裝置免危險

Ensure Safety of Your Electrical Installations Conduct Periodic Inspection Every 5 years



若電力裝置的允許負載量超逾100安培，裝置擁有人必須根據法例最少每5年為裝置安排一次檢測及領取證明書。

>100A



If the approved loading of an electrical installation exceeds 100A, the owner shall arrange inspection, testing and certification of the installation at least once every 5 years.



定期檢測必須由註冊電業承辦商進行。檢測完成後，註冊電業承辦商須簽發定期測試證明書(WR2)。



Periodic inspection must be carried out by a registered electrical contractor, who shall issue a certificate (WR2) after the work.



測試證明書(WR2)須於簽發後兩星期內送交機電工程署加簽，裝置擁有人應妥善保存證明書供署方日後查閱。



The certificate(WR2) shall be delivered to EMSD for endorsement within 2 weeks of the date of certification. The owner shall keep the certificate properly for future inspection by EMSD staff.



電力裝置的擁有人是指管有或控制電力裝置的人，例如公用電力裝置的擁有人包括業主立案法團、物業管理公司和各單位的業主和租客。

An owner of an electrical installation is a person who is in possession or control of the installation. For example, owners of a communal electrical installation shall include incorporated owners, property management companies and all landlords and tenants of individual units.



如裝置擁有人未能於5年限期前完成檢測，即屬違法，最高可處罰款一萬元。

An installation owner, who fails to complete the inspection and testing before the 5-year time limit, commits an offence and is liable to a fine of \$10,000.



## 查詢 Enquiries

電話 Tel.: 1823 傳真 Fax: 2895 4929

網址 Homepage: [www.emsd.gov.hk](http://www.emsd.gov.hk)

正確使用  
Proper Use

+ 定期檢修  
Regular Maintenance

→ 安全用電  
Electrical Safety

機電工程署



EMSD