

Annual Statistics of Water Sample Tests of Fresh Water Cooling Towers (since 2011)

由 2011 年起每年淡水冷卻塔水樣本檢測統計數字

Routine surveillance inspections by EMSD

機電署例行監察巡查

	2011 (since Apr) 2011 年 (4 月底)	2012 2012 年	2013 2013 年	2014 2014 年	2015 2015 年	2016 2016 年	2017 2017 年	2018 2018 年	2019 2019 年	2020 2020 年	2021 2021 年	2022 2022 年	2023 2023 年	2024 2024 年	2025 2025 年
No. of water samples from fresh water cooling towers tested by EMSD (No. of buildings involved) 機電署檢測的淡水冷卻塔水樣本數目 (涉及的建築物數量)	560 (498)	898 (739)	887 (751)	932 (827)	992 (832)	970 (870)	931 (841)	954 (863)	954 (640)	902 (621)	875 (587)	827 (524)	1068 (692)	895 (557)	925 (583)
No. of water samples with total legionella count at or above the upper threshold (i.e. 1,000 cfu/ml) with nuisance notices issued 退伍軍人桿菌總濃度等於或超過其上限值(即每毫升 1 000 菌落)及已發出「妨擾事故通知」的水樣本數目	27	33	25	29	9	32	22	14	16	12	21	23	44	22	19
No. of water samples detected with total legionella count between 10 and 1,000 cfu/ml 退伍軍人桿菌總濃度介乎每毫升 10 菌落至每毫升 1 000 菌落之間的水樣本數目	235	303	294	283	107	240	199	182	203	167	185	187	226	172	151

Electrical & Mechanical Services Department

機電工程署

8 January 2026

2026 年 1 月 8 日